

SUNCOFIRE

SUNCOAST FIRE PROTECTION

☎ 0412 681319 ☎

UNIT 11/8 OXLEY ST. NORTH LAKES. QLD. 4509

ALL MAIL TO: PO BOX 728 NORTH LAKES. QLD. 4509.

Email: suncofire@bigpond.com

ABN: 22 428 298 170. www.suncoastfireprotection.com.au

ROM.NO: 271748
DATE: 24-10-18
PH: 54769788
Contact: TOBY
Memo:
Extras:

RECORD OF MAINTENANCE

TO: CATHODIC ANODES AUSTRALASIA
8 ENDEAVOUR DR
KUNDA PARK. QLD. 4556
ACCOUNTS ADDRESS: jody@cathodicanodes.com.au

ID	TYPE	KG	YR/PT	Kg/Flow	Location	Action Required	Actioned	Pass	Fail	YR/PT	Service Level	
1	ABE	2.5	17	✓	OFFICE UP			PASS			2	
2	ABE	4.5	15	✓	VOLTAGE							1
3	ABE	4.5	15	✓	SHED 3							1
4	CO2	5.0	15	11.25	VOLTAGE							2
5	FHR			6	FRONT							2
6	ABE	2.5	17	✓	OFFICE EXIT DOW							2
7	FHR			3.7	REAR	Replace Nozzle						2
8	ABE	4.5	15	✓	N/EAST							2
9	ABE	2.5	18	✓	MEZZ.							2
10	ABE	4.5	18	✓	MIDDLE							2
11	ABE	4.5	18	✓	MIDDLE							2
12	ABE	4.5	18	✓	NORTH							2
13	ABE	4.5	18	✓	SHED EAST M							2
14	CO2	2.0	16	✓	OFFICE UP							1

Defects/requirements: *Nozzle Replaced*

PROP: WENDY ANN LOWE QBCC LICENCE # 745036
 All work carried out to Australian Standards in compliance with QDC MP 6.1 (AS 1851-2012, AS2444-2001 & all other applicable Standards) The information herein is correct.

Tech Name: **Christopher R Daly**
 Tech sign:
 QBCC Licence: **QBCC 1212292**

THIS IS YOUR RECORD OF MAINTENANCE – PLEASE FILE ON THE PREMISES.

Ross