SUNCOFIRE

SUNCOAST FIRE PROTECTION
UNIT 11/8 OXLEY ST. NORTH LAKES. QLD. 4509
ALL MAIL TO:PO BOX 728 NORTH LAKES.QLD.4509.
ABN: 22 428 298 170. www.suncofire.com.au

☎ 0412 681319 ☎
Email: suncofire@bigpond.com

ROM: 279631
DATE: 13-11-19

RECORD OF MAINTENANCE

TO: CATHODIC ANODES AUSTRALASIA	PH:54769788
8 ENDEAVOUR DR	Contact:TOBY
KUNDA PARK.QLD.4556	Memo:
ACCOUNTS ADDRESS: jody@cathodicanodes.com.au	Extras:

ID	TYPE	KG	YR/PT	Kg/Flow	Location	Action Required	Actioned	Pass	Fail	YR/PT	Service Level
1	ABE	2.5	17		OFFICE UP			✓			2
2	ABE	4.5	15		VOLTAGE			✓			2
3	ABE	4.5	15		SHED 3			✓			2
4	CO2	5.0	15	11.32	VOLTAGE			✓			2
5	FHR				FRONT			✓			2
6	ABE	2.5	17		OFFICE EXIT DOW			✓			2
7	FHR			.99	REAR			✓			2
8	ABE	4.5	15		N/EAST			✓			2
9	ABE	2.5	18		MEZZ.			✓			2
10	ABE	4.5	18		MIDDLE			✓			2
11	ABE	4.5	18		MIDDLE			✓			2
12	ABE	4.5	18		rear			✓			2
13	ABE	4.5	18		SHED EAST M			✓			2
14	CO2	2.0	16	4.92	OFFICE UP			✓			2

Defects/requirements:

PROP: WENDY ANN LOWE QBCC LICENCE # 745036
All work carried out to Australian Standards in compliance with **QDC MP 6.1 (AS 1851-2012.AS2444-2001** & all other applicable Standards) The information herein is correct.

THIS IS YOUR RECORD OF MAINTENANCE – PLEASE FILE ON THE PREMISES.

Tech Name:
Tech sign: David Doby
QBCC Licence: 1248915