

# SUNCOFIRE

**SUNCOAST FIRE PROTECTION**  
 UNIT 11/8 OXLEY ST. NORTH LAKES. QLD. 4509  
 ALL MAIL TO: PO BOX 728 NORTH LAKES. QLD. 4509.  
 ABN: 22 428 298 170. [www.suncofire.com.au](http://www.suncofire.com.au)

☎ 0412 681319 ☎

Email: [suncofire@bigpond.com](mailto:suncofire@bigpond.com)

## RECORD OF MAINTENANCE

<b>TO: CATHODIC ANODES AUSTRALASIA</b>	ROM: 291235
<b>ENDEAVOUR DR 8</b>	DATE: 19/5/21
<b>KUNDA PARK. QLD. 4556</b>	PH: 54769788
<b>A/C EMAIL: lang@cathodicanodes.com.au</b>	Contact: TOBY
	Memo:
	Extras:

ID	TYPE	KG	YR/PT	Kg/Flow	Location	Defects/Action Req.	Actioned date	Pass	Fail	YR/PT	Service Level
1	ABE	2.5	17		OFFICE UP			P			1
2	ABE	4.5	20		VOLTAGE			P			1
4	CO2	5.0	20	11.06	VOLTAGE			P			1
5	FHR				FRONT			P			1
6	ABE	2.5	17		OFFICE EXIT DOWN			P			1
7	FHR				REAR			P			1
8	ABE	4.5	20		N/EAST			P			1
9	ABE	2.5	18		MEZZ.			P			1
10	ABE	4.5	18		MIDDLE			P			1
11	ABE	4.5	18		MIDDLE			P			1
12	ABE	4.5	18		REAR			P			1
13	ABE	4.5	18		SHED EAST M			P			1
14	CO2	2.0	16/1		OFFICE UP	Due test					

<b>Defects/req:</b>	<b>Supplied:</b>

**PROP: WENDY ANN LOWE QBCC LICENCE # 745036**  
 All work carried out to Australian Standards in compliance with QDC MP 6.1 (AS 1851-2012, AS 2444-2001 & all other applicable Standards) The information herein is correct.

**THIS IS YOUR RECORD OF MAINTENANCE – PLEASE FILE ON THE PREMISES.**

Tech Name: Thomas White
Tech sign: _____
QBCC Licence: K129372